

**UNIVERSITY OF TOLEDO
FACILITIES AND CONSTRUCTION**

Section:	Plumbing	Procedure Number:	P-04
Subject:	Maintenance of Clinical Air Compressors	Effective Date:	January 1980
		Revised Date:	November 2016
Facilities Officer:	<i>Mitchell North</i>	Reviewed Date:	February 2023

Standard Operating Procedure

All air compressors will be maintained in accordance with the manufacturer's recommendations and specifications.

Purpose

To provide and maintain proper air pressure throughout the institution.

Procedure

1. Daily checks of air compressors will be made and recorded by the Central Control Operators on second and third shift. Report any unusual conditions directly to their immediate supervisor.
2. All components will be visually checked weekly by the Plumbing staff and recorded on log sheet.
3. Lubrication and repairs will be performed as required by the Plumbing staff or outside contractor if needed.