


**UNIVERSITY OF TOLEDO  
FACILITIES AND CONSTRUCTION**

<b>Section:</b>	<b>Electrical/Electronics</b>	<b>Procedure Number:</b>	<b>E-19</b>
<b>Subject:</b>	<b>Inspection of Surgery Extension Cords</b>	<b>Effective Date:</b>	<b>May 1981</b>
		<b>Revised Date:</b>	<b>December 2019</b>
<b>Facilities Officer:</b>		<b>Reviewed Date:</b>	<b>February 2023</b>

**Standard Operating Procedure**

Extension cords in the surgical area will be inspected on a regular basis.

**Purpose**

To ensure electrical integrity of surgical extension cords.

**Procedure**

Monthly:

1. Visually inspect.
2. Perform voltage test and record.
3. Submit all recordings and report any unusual conditions to the Electrical Manager.