


**UNIVERSITY OF TOLEDO
FACILITIES AND CONSTRUCTION**

Section:	Electrical/Electronics	Procedure Number:	E-19
Subject:	Inspection of Surgery Extension Cords	Effective Date:	May 1981
		Revised Date:	December 2019
Facilities Officer:		Reviewed Date:	December 2019

Standard Operating Procedure

Extension cords in the surgical area will be inspected on a regular basis.

Purpose

To ensure electrical integrity of surgical extension cords.

Procedure

Monthly:

1. Visually inspect.
2. Perform voltage test and record.
3. Submit all recordings and report any unusual conditions to the Electrical Manager.