


**UNIVERSITY OF TOLEDO  
FACILITIES AND CONSTRUCTION**

<b>Section:</b>	<b>HVAC</b>	<b>Procedure Number:</b>	<b>HVAC-14</b>
<b>Subject:</b>	<b>Air Dryer Maintenance - HSC</b>	<b>Effective Date:</b>	<b>January 1980</b>
		<b>Revised Date:</b>	<b>November 2016</b>
<b>Facilities Officer:</b>		<b>Reviewed Date:</b>	<b>December 2019</b>

**Standard Operating Procedure**

Maintenance on air dryers will be performed in accordance with the manufacturer's recommendations and specifications.

**Purpose**

To ensure moisture free air.

**Procedure**

Quarterly:

1. Clean compressor and condenser.
2. Visual and noise checks.