


**UNIVERSITY OF TOLEDO
FACILITIES AND CONSTRUCTION**

| | | | |
|----------------------------|---|--------------------------|----------------------|
| Section: | Plumbing | Procedure Number: | P-02 |
| Subject: | Maintenance of Domestic Water Booster Pump | Effective Date: | January 1980 |
| | | Revised Date: | November 2016 |
| Facilities Officer: |  | Reviewed Date: | December 2019 |

Standard Operating Procedure

Domestic water booster pumps will be maintained in accordance with the manufacturer's recommendations and specifications.

Purpose

To provide and maintain proper water pressure throughout all buildings.

Procedure

1. Daily checks of all domestic booster pumps will be made and recorded by the Operating Engineers on each shift. Report any unusual conditions directly to the immediate supervisor.
2. All components will be visually checked on a quarterly basis by the Plumbing staff.
3. Lubrication and repairs will be performed as required by the Plumbing staff.